



Building Services
808 West Spokane Falls Blvd
Spokane WA 99201-3343
(509) 625-6300

ME-04
Gas Piping for
Moved Meters

The City and County of Spokane will allow Avista Utilities gas street crews to do limited gas piping when they relocate a gas meter. The following conditions and limitations will apply to any gas piping done by Avista Utilities gas street crews:

1. A mechanical permit for gas piping is required (a mechanical permit for underground gas piping downstream from the meter is already required).
2. Any gas piping done by Avista Utilities gas street crews is to be limited to no more than 5 feet in length and must be outside of the building. No gas piping is to be done inside the building.
3. The Avista Utilities gas street crews can relight pilots put out when the gas is shut off, but cannot make any adjustments to the appliances.
4. If any adjustment is required for the gas appliances, the owner is to be notified in writing to contact either an Avista Utilities gas serviceman or a mechanical contractor.